

Bidding Addendum

Addendum No. 1 for Department of Behavioral Health and Developmental Services, Department of Veteran Services, Amelia Veterans Cemetery, 10300 Pridesville Road, Amelia, VA 23002 Road Repairs and Resurfacing, IFB 12-12.

To: All Bidding Document Holders of Record

From: Wiley|Wilson
Richmond, Virginia

This Addendum contains 2 pages and listed attachments and forms a part of the bidding documents and modifies the Project Manual and Drawings dated June 25, 2012, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

PRE-BID CONFERENCE

A pre-bid meeting was held on Monday, July 2, 2012 at 10:00 a.m. at the project site. A list of attendees and the agenda for the meeting are attached.

SPECIFICATIONS:

Delete the current Bid Form in its entirety and **Replace** with the Bid Form (in its entirety) in Addendum 1 attachments.

PREBID QUESTIONS:

1. "Per the pavement patch detail with overlay will the existing stone base be removed and replaced with a new 6" 21B base? Or will it only be removed and replaced if found to be unsuitable?"
Stone base shall be tested for suitability. The stone base does not require replacement if it found to be acceptable for reuse based on the testing results.
2. "Will silt fence be required on both sides of the maintenance road?"
Yes, to prevent sediment from entering the drainage ditch on the west side and from washing down the slope on the east side.
3. "Will a prime coat be required for the maintenance road and the asphalt overlay butt joints as shown?"
Yes.

4. "In the base bid we are to exclude work in Additive Bid Items 1 – 3. What are and where can we find these items?"

See revised Bid Form provided with Addendum 1 for correction of Additive Bid Items 1-3.

5. "What should be included in the per square yard price for asphalt overlay? Truck, paving, topsoil, seeding and mulch? Also the same square yard price for asphalt patch?

Excavation, stone, truck asphalt and saw cut?


Yes.

End of Addendum No. 1

ATTACHMENTS:

Revised Bid Form
Pre Bid Conference Agenda

WILEY|WILSON



Norman Downey, P.E.